

AMIKON TECHNICAL INTELLIGENCE

Product Data Sheet

Bently Nevada 74712-03-11-02-00
High-temperature two-wire Seismoprobe velocity transducer



PRODUCT	THREAD	TOTAL LENGTH	SYSTEM
9200 and 74712 Seismoprobe Velocity Transducers	Isolated circular M10X1 base	Top-mount connector	9200 and 74712 Seismoprobe Velocity Transducers

Bently Nevada 74712-03-11-02-00 is a High-temperature two-wire Seismoprobe velocity transducer used as the sensing or signal component in the matching 9200 and 74712 Seismoprobe Velocity Transducers system. Complete measurement requires compatible system components and the exact ordered electrical or loop configuration.

01

CURRENT PAGE PARAMETERS

Product Model	74712-03-11-02-00
Product Parameters	High-temperature two-wire Seismoprobe velocity transducer; Isolated circular M10X1 base; high-temperature
Tariff Code	9031809090
Place of shipment	Xiamen, China
Estimated Shipping Size	7.6 x 5.1 x 5.1 cm
Product Type	9200 and 74712 Seismoprobe Velocity Transducers
Case Thread	Isolated circular M10X1 base
Unthreaded Length	90 degrees mounting angle
Total Length	Top-mount connector
Cable and Connector	Top-mount connector
Estimated Probe Temperature Range	Refer to official manufacturer datasheet
Series-level Typical Weight	0.48 kg

Source scope: official Bently Nevada 141626 Rev. V, current product record, tariff and shipment fields. Technical configuration is limited to this exact model.

02 ORDERING CODE VERIFICATION

74712	High-temperature two-wire Seismoprobe
03	90 degrees mounting angle
11	Isolated circular M10X1 base
02	Top-mount connector
00	No approvals

03 SYSTEM ROLE AND APPLICATIONS

The ordered 74712-03-11-02-00 configuration is used only with the compatible 9200 and 74712 Seismoprobe Velocity Transducers system. Maintain the specified system length, mounting, connector or output, and approval option.

- Bearing-housing vibration monitoring
- High-temperature machinery vibration measurement
- Machine casing vibration monitoring
- Velocity-based protection monitoring

04 OFFICIAL INSTALLATION FACTS

- Use the specified Isolated circular M10X1 base mounting configuration.
- Maintain the ordered Top-mount connector system length.
- Preserve Top-mount connector and protect all connections.
- Use the manufacturer drawing and controlled procedure for installation.

05 OFFICIAL DOCUMENTATION

[9200 and 74712 Seismoprobe Velocity Transducers System Datasheet - 141626 Rev. V](#)

Controlled references remain in the official data sheet and manufacturer documentation. Obtain current revisions through the manufacturer media library.

AMIKON PRODUCT SUPPORT

Amikon Limited

INFO@AMIKON.CN