

AMIKON TECHNICAL INTELLIGENCE

Installation Instructions

Siemens 6EP1332-1SH71

Stabilized Power Supply Module

01 CONFIRM THE CONFIGURATION

Article Number	6EP1332-1SH71
Product	PM1207, 24 V DC / 2.5 A
Family	SIMATIC S7-1200 PM1207
Weight	0.300 kg
Origin	Romania

02 BEFORE INSTALLATION

- Only qualified personnel may install and commission the power supply.
- Isolate the 120/230 V AC supply before wiring or removal.
- Mount on the documented TH35 rail or wall arrangement with terminals at the top.
- Maintain at least 20 mm ventilation clearance above and below the unit.
- Verify protective grounding, 24 V DC polarity and output voltage before connecting the load.

03 COMMISSIONING AND REPLACEMENT

- Inspect mounting, connectors, terminals, wiring and grounding before applying power.
- Verify the configured function against the approved hardware configuration and Siemens documentation.
- Confirm normal operation and diagnostic status before placing the equipment into service.
- Record the exact article number, installation location and commissioning results for maintenance.
- Replacement must preserve the documented electrical, mechanical and system compatibility requirements.

04 CONTROLLED SOURCE

Manufacturer	Siemens AG
Exact Article	6EP1332-1SH71
Official Source	Siemens Industry Mall and official PDF
Document Use	Installation reference - not a substitute for controlled instructions