

AMIKON TECHNICAL DOCUMENTATION

Installation Reference

Siemens 6SL3055-0AA00-3LA0 SINAMICS terminal interface module
Qualified drive-service personnel and controlled documentation required

DOCUMENTATION REFERENCE

6SL3055-0AA00-3LA0

SINAMICS S120 control systems
SIEMENS

SAFETY AND SCOPE

Use 6SL3055-0AA00-3LA0 only in the documented SINAMICS S120 control systems arrangement. Isolate hazardous energy, observe the Siemens discharge time, use ESD controls, and follow the approved site procedure.

01

IDENTITY CHECK BEFORE WORK

Complete identifier	6SL3055-0AA00-3LA0
Product family	SINAMICS S120 control systems
Component class	SINAMICS terminal interface module
Electrical class	24 V DC supply
Installed section	Drive I/O section
Connections	Digital, analog and system terminals

02

BEFORE REMOVAL

- Confirm the exact 6SL3055-0AA00-3LA0 article, board revision, section position and controlled drawing.
- Complete the site's lockout, isolation, discharge and absence-of-voltage verification procedure.
- Photograph and label digital, analog and system terminals, cable routing, grounding and adjacent assemblies.
- Protect the assembly from electrostatic discharge, contamination, impact and connector damage.

AMIKON PRODUCT SUPPORT

Amikon Limited +86-18020776786 INFO@AMIKON.CN

AMIKONG.COM

03

MODEL-SPECIFIC INSTALLATION WORKFLOW

1

CONFIRM SCOPE

Verify 6SL3055-0AA00-3LA0, the drive i/o section, revision and controlled drawing before work.

2

ISOLATE

Apply the site safety procedure for 24 V DC supply and prove the drive is safe to handle.

3

DOCUMENT

Record digital, analog and system terminals, connector keys, cable labels, grounding and mechanical position.

4

REMOVE

Use ESD protection and the Siemens service procedure; support the SINAMICS terminal interface module and do not force plugs.

5

COMPARE

Match the replacement article, Signal-level terminal load, interfaces and mechanical design.

6

INSTALL

Seat the assembly evenly, restore documented connections, shields, earth paths and cooling provisions.

7

COMMISSION

Test channel assignment and signal states. Review diagnostics before releasing the affected drive function.

OFFICIAL DOCUMENT APPLICABILITY

No directly applicable Siemens installation PDF was available for 6SL3055-0AA00-3LA0. Use the controlled project documentation and obtain Siemens confirmation for any unresolved hardware or firmware condition.

04

PRE-ENERGIZATION AND HANDOVER CHECKLIST

Identifier	Exact 6SL3055-0AA00-3LA0 article and product-family identity match the approved replacement record
Mechanical	DIN-rail terminal module is correctly seated, retained and free from transport damage
Connections	Digital, analog and system terminals and protective-earth paths match the removal record
Electrical	24 V DC supply and Signal-level terminal load agree with the installed drive section
Configuration	Required parameters, firmware conditions and controlled project settings are approved
Commissioning	Test channel assignment and signal states
Records	Photos, article number, revision, diagnostics and test results are retained in the maintenance record

05

OFFICIAL REFERENCE AND LIMITATIONS

SIEMENS MANUFACTURER REFERENCE

Siemens product-family documentation and controlled site records

Use only where the official family, installed section and exact 6SL3055-0AA00-3LA0 configuration agree. Terminal functions, firmware compatibility, torque values and final acceptance criteria must come from the applicable Siemens manual or controlled project documentation.

DO NOT INFER MISSING SPECIFICATIONS

Do not infer undocumented connector functions, electrical ratings, parameter compatibility, cooling requirements or commissioning limits from appearance or a partial article number.

AMIKON PRODUCT SUPPORT

Amikon Limited +86-18020776786 INFO@AMIKON.CN AMIKONG.COM