

MANUFACTURER DOCUMENT PACKAGE

Manufacturer's Manual

Reference package for procurement and maintenance review

BENTLY NEVADA

129525-0050-02

SELECTED MANUFACTURER TECHNICAL REFERENCE

Used with the applicable Bently Nevada Orbit 60 Series Temperature Module Datasheet 137M0706 configuration.

REFERENCE PACKAGE

OFFICIAL DOCUMENT

Selected official manufacturer pages follow this cover.

Source: Bently Nevada Orbit 60 Series Temperature Module Datasheet 137M0706

ORBIT 60 SERIES

Temperature Module

Datasheet

Cordant™

I37M0705 Rev. C



Description

TC/RTD and Isolated TC Temperature Modules

The primary purpose of temperature modules is to interface to the temperature transducers and convert the signal into a digital representation. These modules condition and digitize the inputs at a rate that completely encompasses the signal content and allows for removal of typical noise sources.

The Bently Nevada™ Orbit 60 Series TC/RTD Temperature Input Modules provide six channels of either Thermocouple (TC) or Resistive Temperature Detector (RTD) temperature input sensors.

The Orbit 60 Series Isolated TC Temperature Input Modules provide six isolated channels of Thermocouple (TC) input sensors.

Each channel of the Orbit 60 Series TC/RTD and isolated TC input modules are individually configurable for sensor type and range using Orbit Studio configuration software.

The RTD/TC inputs reference the internal system ground, and for this reason, should only connect to transducers isolated at the sensing end. Each Isolated TC input is isolated from system common and other input channels within the module.

These modules occupy a single slot. The module OK LEDs indicate proper functioning and the LINK LEDs indicate good system communication. Six Channel Status LEDs on the utility side of the module indicate a connected sensor in OK condition.

Both the TC/RTD and Isolated TC input modules are offered with either internal or external termination options.



Baker Hughes 

TC/RTD Temperature

Temperature	
Thermocouple (TC) Temperature	
Thermocouple	Type J, K, E, T
Channel Supported	6
Nominal Error	±1C
Max Error	±3C
RTD Temperature	
RTD Type	Pt100 (385), Pt100 (392), Ni120, Cu10
Max Error	±1C, except Cu10 ±3C
 To achieve +/−3C MAX Error with Cu10 RTD with external termination wiring, a calibration process must be completed.	
 Platinum RTD's with 0.00385 alphas are the worldwide industrial standard and are recommended for all applications.	
Power Consumption	
Maximum	6 W
Typical	3 W
LEDs	
Channel Status LED (Rear Utility Side)	1 per unit channel indicates when the connected sensor is in an OK condition
Module OK LED	Indicates when the module is functioning properly

Temperature	
System Communication LED	Indicates when the module is communicating to the rest of the system
Physical Characteristics	
Required Rack Space	1 Slot
Environmental Limits	
Chassis Operating Temperature Range	3U Chassis: −30°C to +70°C (−22°F to 158°F)  6U Chassis: −30°C to +65°C (−22°F to 149°F)  (indoor use only)
Module Temperature Rating Certification	 Temperatures over 50°C (122°F) require forced air convection with a minimum airspeed of 0.5 m/s.  When using a Bridge module in a 3U chassis, temperatures over 55°C (131°F) require forced air convection with a minimum airspeed of 0.5 m/s.  You must still meet the Chassis Operating Temperature Range defined above.
Storage Temperature Range	−40°C to +85°C (−40°F to 185°F)

Accessories

Part Number	Description
60X/BTC01	Buffered Transducer Breakout Kit
60X/ETA01	Ext Termination Adapter - Universal
60X/ETB02	Ext Termination Block - TC
I29525-0005-02	EXT Termination Block Cable 5 ft (1.5 m)
I29525-0007-02	EXT Termination Block Cable 7 ft (2.1 m)
I29525-0010-02	EXT Termination Block Cable 10 ft (3.0 m)
I29525-0025-02	EXT Termination Block Cable 25 ft (7.5 m)
I29525-0050-02	EXT Termination Block Cable 50 ft (15 m)
I29525-0100-02	EXT Termination Block Cable 100 ft (30.5 m)



When using ETB temperature modules with thermocouple (TC) sensors, installation of a 60X/ETB02 block is required to ensure proper functionality.

External Galvanic Isolators

Part Number	Description
I03M7134	3-pin Transducer Isolator
I03M7134	2-pin Transducer Isolator
I54M1361	Thermocouple Isolator
I03M7138	RTD Isolator



Ext Termination Block - TC cannot be used with Internal Termination I/O modules.

External Barriers

Part Number	Description
I75502	3-pin Transducer Barrier
I77241	2-pin Velomitor Barrier
I75990 or I70M3559	Thermocouple Barrier
I70M3559	RTD Barrier