

Installation Instructions

3BHB003230R0101 GVC704 AE01

igct module

ABB Advant OCS and Advant-800xA

Before work begins

- 01 Confirm the exact 3BHB003230R0101 GVC704 AE01 article number and installed equipment position.
- 02 Place the equipment in a safe state, isolate all energy sources and follow the applicable ABB discharge or lockout procedure.
- 03 Record terminals, connectors, signal cables, cooling provisions and protective-earth conductors.
- 04 Use ESD controls and qualified industrial-service personnel throughout the replacement.

Model-specific connection checks

Voltage Rating	4500 V (VCES)
Current Rating	2100 A (ITAVM)
Power Losses	1.0-2.5 kW
Operating Temperature	-40°C to +125°C
Storage Temperature	-40°C to +85°C
Humidity	< 95% RH (non-condensing)
Exact Article Code	3BHB003230R0101 GVC704 AE01
Device Designation	GVC704 AE01
Product Family	ABB Advant OCS and Advant-800xA
Semiconductor Type	IGCT

Installation sequence

- Inspect the replacement for transport damage, contamination, bent pins and altered keying.
- Install without forcing connectors or terminals; restore all shields, grounds and cooling provisions.
- Secure power and signal connections under the applicable manufacturer procedure.

Commissioning and return to service

- 01 Power semiconductor module.
- 02 Check insulation and protective-earth continuity before energising..
- 03 Restore auxiliary and main power in the approved sequence..
- 04 Observe controller, interface and equipment diagnostics..
- 05 Test the connected signal, network, motor or power function at a controlled operating point..
- 06 Record the final article number, test results and maintenance approval..

This AMIKON installation reference supplements the applicable ABB controlled documentation and the site safety procedure. Warranty: 12 months from AMIKON.