

Installation Instructions

3BHB021400R0002 5SHY4045L0004 3BHB026114R0001 5SHY5055L0002

integrated gate commutated thyristor

ABB Drives

Before work begins

- 01 Confirm the exact 3BHB021400R0002 5SHY4045L0004 3BHB026114R0001 5SHY5055L0002 article number and installed equipment position.
- 02 Place the equipment in a safe state, isolate all energy sources and follow the applicable ABB discharge or lockout procedure.
- 03 Record terminals, connectors, signal cables, cooling provisions and protective-earth conductors.
- 04 Use ESD controls and qualified industrial-service personnel throughout the replacement.

Model-specific connection checks

Exact Article Code	3BHB021400R0002 5SHY4045L0004 3BHB026114R0001 5SHY5055
Device Designation	5SHY4045L0004 3BHB026114R0001 5SHY5055L0002
Product Family	ABB Drives
Semiconductor Type	thyristor / diode
Switching Position	Drive power converter stage
Gate Interface	Matched ABB gate unit
Cooling Interface	Converter heat-sink mounting
Electrical Matching	Exact voltage and current class
Installation Format	Power semiconductor module
Protective Check	Insulation and gate-circuit test

Installation sequence

- Inspect the replacement for transport damage, contamination, bent pins and altered keying.
- Install without forcing connectors or terminals; restore all shields, grounds and cooling provisions.
- Secure power and signal connections under the applicable manufacturer procedure.

Commissioning and return to service

- 01 Installed drive hardware list.
- 02 Check insulation and protective-earth continuity before energising..
- 03 Restore auxiliary and main power in the approved sequence..
- 04 Observe controller, interface and equipment diagnostics..
- 05 Test the connected signal, network, motor or power function at a controlled operating point..
- 06 Record the final article number, test results and maintenance approval..

This AMIKON installation reference supplements the applicable ABB controlled documentation and the site safety procedure. Warranty: 12 months from AMIKON.