

MANUFACTURER DOCUMENT PACKAGE

Manufacturer's Manual

3500 SYSTEM

3500/93 135799-02

3500 SYSTEM DISPLAY

Applicable product family: Bently Nevada 3500 machinery protection systems


OFFICIAL SOURCE

3500-93 135799-02.pdf

The following pages are selected from the supplied manufacturer document and retain their original page content.

Specifications and Ordering Information

3500/93 System Display



Description

The 3500/93 System Display is designed to meet the requirements of American Petroleum Institute Standard 670 and provide local or remote visual indication of all 3500 Machinery Protection System information residing in the rack including:

-  System Event List
-  Alarm Event Lists
-  All Channel, Monitor, Relay Module, Keyphasor? Module or Tachometer Module data

The 3500/93 System Display is configured using 3500 Rack Configuration Software. The display can be mounted in any of four ways:

1. **Face Mounting** – display installs directly over the front panel of any full size 3500 rack using a special hinged support. This permits access to the rack's buffered output connectors and user-interface buttons and switches without disconnecting or disabling the display.

Note: For this mounting option only, the Display Interface Module (DIM) must be installed in slot 15 (right-most slot) of the rack. The Face Mounting option is not compatible with the 3500 Mini-rack.

2. **19-inch EIA Rack Mounting** – display is mounted on 19-inch EIA rails and located up to 100 feet away from the 3500 System. (Up to 4000 feet away from the 3500 System when using the

External Power Supply).

3. **Panel Mounting** – display is mounted in a panel cutout located in the same cabinet or up to 100 feet away from the 3500 System. (Up to 4000 feet away from the 3500 System when using the External Power Supply).
4. **Independent Mounting** – display is mounted flush against a wall or panel and located up to 100 feet away from the 3500 System. (Up to 4000 feet away from the 3500 System when using the External Power Supply).

Up to two displays can be connected to each 3500 rack and each display requires one empty 3500 rack slot for insertion of its corresponding DIM. When the display is not face-mounted, the cable connection between the DIM and the Display can be made from the front of the 3500 rack or from the I/O module at the rear of the rack.

Applications that require a cable longer than 100 feet must use the External Power Supply and Cable Adapter. Applications that use the back lighted Display Unit must use the External Power Supply. There are two External Power Supplies: one for connection to 115 Vac and the other for connection to 230 Vac.

The External Power/Terminal Strip Mounting Kit eases installation of External Power Supplies. The External Power/Terminal Strip Mounting Kit is designed to fit in the Independent Mount Housing. The Kit streamlines installation of an External Power Supply in both the Independent Mount Housing or a user supplied housing.

Specifications

Inputs

Power Consumption: 15.5 watt maximum (Display Unit & Display Interface Module); 5.6 watt maximum (-01 Display Unit); 12.0 watt maximum (-02 Display Unit).

Data Types: Collects data, such as current values and current alarm status, via a high speed internal network.

Outputs

Display Interface Module

OK LED: Indicates when the Display Interface Module is operating properly.

TX/RX LED: Indicates when the Display Interface Module is communicating with other modules in the 3500 rack.

Display Unit

Unit OK LED: Indicates when the Display Unit is operating properly.

Rack OK LED: Indicates rack is in OK status, all channels are OK.

Rack Alert LED: Indicates rack is in Alert status, at least one channel is in Alert.

Rack Danger LED: Indicates rack is in Danger status, at least one channel is in Danger.

OK LED (8): Indicates displayed channel(s) above the LED is in OK status.

Alert LED (8): Indicates displayed channel(s) above the LED is in Alert status.

Danger LED (8): Indicates displayed channel(s) above the LED is in Danger status.

New Alarm LED: Indicates new alarm has been detected since the last acknowledgment.

Reflective 640 x 200 Dots LCD: Displays data in graphical and text format. LCD module is reflective FSTN dot matrix type without backlight. **Ambient white light is required for acceptable visibility.** Best visibility is under indirect sunlight conditions, LCD visibility decreases with corresponding decrease in ambient light level. LCD exhibits acceptable visibility under normal office lighting levels.

Transflective 640x200 Dots LCD: Displays data in graphical and text format. LCD module is transflective FSTN dot matrix type with white electroluminescent backlight.

Communication between the Display Unit and the Display Interface Module

Hardware: RS422 Interface.

Protocol: Supports Bently Nevada proprietary protocol and Modbus® protocol based on AEG PI-MBUS-300 Rev. E Reference Manual.

Channel update rate: 1 second, typical.

Environmental Limits

Display Interface Module & I/O Module

Operating Temperature: -30°C to +65°C (-22°F to +150°F).

Storage Temperature: -40°C to +85°C (-40°F to +185°F).

Humidity: 95%, noncondensing.

Display Unit

Operating Temperature: -20°C to 65°C (-4°F to 149°F).

Storage Temperature: -30° C to 80° C
(-22° F to 176° F).

Humidity: 95%, noncondensing.

Dimensions (Height x Width x Depth): 241.3 mm x 24.4 mm x 99.1 mm
(9.50 in x 0.96 in x 3.90 in).

Weight: 0.38 kg (0.84 lb.).

CE Mark Directives

EMC Directives:

EN50081-2: Radiated Emissions
EN 55011, Class A
Conducted Emissions
EN 55011, Class A

EN50082-2: Electrostatic Discharge
EN 61000-4-2, Criteria B
Radiated Susceptibility
ENV 50140, Criteria A
Conducted Susceptibility
ENV 50141, Criteria A
Electrical Fast Transient
EN 61000-4-4, Criteria B
Surge Capability
EN 61000-4-5, Criteria B
Magnetic Field
EN 61000-4-8, Criteria A
Power Supply Dip
EN 61000-4-11, Criteria B
Radio Telephone
ENV 50204, Criteria B

Low Voltage Directives:

EN 61010-1 Safety Requirements

Display Unit

Dimensions (Height x Width x Depth): 203.2 mm x 412.8 mm x 31.2 mm
(8.00 in x 16.25 in x 1.23 in).

Weight: 2.1 kg (4.6 lb.).

Rack Space Requirements

Main Board: 1 full-height front slot.

I/O Modules: 1 full-height rear slot.

Hazardous Area Approvals

CSA/NRTL/C: Class I, Division 2, Groups A through D.

Physical

Display Interface Module

Dimensions (Height x Width x Depth): 241.3 mm x 24.4 mm x 241.8 mm
(9.50 in x 0.96 in x 9.52 in).

Weight: 0.82 kg (1.82 lb.).

Display Interface I/O Module