


FIELD INSTALLATION QUICK GUIDE

Installation Instructions

6SX7005-0AF00

SLM SIMOLINK monitor



PRODUCT	6SX7005-0AF00
FAMILY	SIMOVER Masterdrives diagnostics
FUNCTION	SLM SIMOLINK monitor
STATUS	Verify exact installed equipment

Prepared by Amikon Limited from S7-300 documentation. This guide supplements the complete manufacturer manual and site procedure.

01

CONFIRM THE ORDERED CONFIGURATION

Product Type	SLM SIMOLINK monitor
Bus Interface	SIMOLINK
Host Interface	Personal computer
Diagnostic Function	SIMOLINK network monitoring
Supply Source	External 24 V DC
Mounting Format	Compact enclosure

02

PREPARATION AND CONNECTION

- Confirm the complete 6SX7005-0AF00 article number and installed revision.
- Isolate applicable electrical and process energy using the approved site procedure.
- Record every connector, cable, terminal, shield and protective-earth connection before removal.
- Install without forcing keyed parts, then secure terminals, latches, fasteners and cable supports.

OFFICIAL INSTALLATION REFERENCE

Note

These technical data are intended for general information purposes.
Please observe the operating instructions and the references indicated on the products for installation, operation and maintenance.

® BERO, COMBIMASTER, MICROMASTER, ProTool, SICOMP, SIMADYN, SIMATIC, SIMATIC HMI, SIMODRIVE, SIMOLINK, SIMOREG, SIMOTION, SIMOVERT, SITOP, STEP-STRUC and USS are Siemens registered trademarks. All other products and system names in this catalog may be (registered) trademarks. Use of these names by third parties for their own purposes may therefore infringe upon the trademark owners' rights.

- The technical data, selection and ordering data (Order Nos.), accessories and availability are subject to alteration.
- All dimensions in this catalog are stated in mm (inches).

© Siemens AG 2003

04 COMMISSIONING CHECKS

- 01 Confirm product identity and mechanical seating.
- 02 Verify the documented supply before energising.
- 03 Inspect polarity, shielding and protective-earth connections.
- 04 Restore power in the approved sequence and observe status indications.
- 05 Test each connected input, output or communication path.
- 06 Record diagnostics and functional-test results before return to service.

05 CONTROLLED DOCUMENT

Official source	Siemens official product documentation
Product record	6SX7005-0AF00
Manufacturer	S7-300
Warranty	12 months from AMIKON
Support	INFO@AMIKON.CN

AMIKON PRODUCT SUPPORT

+86-18020776786

INFO@AMIKON.CN

AMIKONG.COM