

MANUFACTURER DOCUMENT PACKAGE

Manufacturer's Manual

Reference package for procurement and maintenance review

DELTA V

KC4011X1-BP1

16-CHANNEL AI TERMINAL BLOCK

Used with the applicable DeltaV S-series traditional I/O configuration.

REFERENCE PACKAGE

OFFICIAL DOCUMENT

Selected official manufacturer pages follow this cover.

Source: Emerson official manufacturer documentation

KC4011X1-BP1 4-Wire AI 16-Channel Terminal Block

Hazardous Atmosphere



II 3G Ex ec ic IIC Gc
FM19ATEX0173U
IECEx FMG 19.0019U
FM21UKEX0017U



CL. 1 Zn 2 AEx/Ex ec ic IIC Gc
FM17US0286U
FM17CA0145U

Power Specifications

Field Circuit 30 VDC at 500 mA/Channel

Environmental Specifications

Ambient Temperature	-40 °C to +70 °C
Shock	10 g half-sine wave for 11 ms
Vibration	1 mm peak to peak from 2 to 13.2 Hz; 0.7 g from 13.2 to 150 Hz
Airborne Contaminants	ISA-S71.04 –1985 Airborne Contaminants Class G3
Relative Humidity	5 to 95% Non-Condensing
Terminal block key position	A6

Note: Refer to the product label for serial number and location and date of manufacture.

Warning: This product has specific instructions for installation, removal and operation in hazardous areas. Refer to document 12P2046 *"DeltaV™ Scalable Process System Zone 2 Installation Instructions"*. Other installation instructions are

available in the *"DeltaV™ S-series and CHARMs Hardware Installation"* manual.

Removal and Insertion

Terminals Block can be added or removed with System Power applied only when no I/O Card is installed, and no field wiring is connected to the terminal.

A rotary keying system ensures compatibility between I/O cards and terminal blocks after installation is complete. The terminal block must have the keys set for the I/O card with which it is to be used.

Maintenance and Adjustment

This unit contains no user serviceable parts and should not be disassembled for any reason. Calibration is not required.

Other Safety Approvals

