

AMIKON TECHNICAL DOCUMENTATION

Installation Instructions

ICS Triplex T8082D

Trusted Software Key Toolset

KEY FORM	ENVIRONMENT	CONFIGURATION	PLATFORM
Software	IEC 61131 Toolset	SYSTEM.INI	Trusted

For qualified personnel only. This installation summary is not a substitute for the controlled manufacturer procedure, system safety plan or approved site isolation requirements.

01

BEFORE INSTALLATION

Exact option	Confirm T8082D and the software key variant.
Entitlement	Verify legitimate key, activation and transfer conditions.
Workstation	Check the actual release and approved legacy environment.
Project records	Back up configuration, logic and I/O mappings.
Safety notice	Review current guidance for Advisory 2020-08-002.

02

PREPARATION AND BOUNDARIES

- The documented software license must be protected or transferred before uninstalling the Toolset. Preserve the original project and configuration before modifying the workstation.
- Use the release-specific installation guide and current manufacturer safety guidance. This reference does not authorize controller downloads or live program changes.

03
INSTALLATION AND COMMISSIONING

01	Confirm T8082D, the actual release, legitimate entitlement and approved workstation compatibility.
02	Protect or transfer the software license before uninstalling, and back up all approved project files.
03	Have the authorized license holder review the terms and install the legitimate matching software package.
04	Complete the documented legitimate activation process and confirm license status without exposing registration material.
05	Review SYSTEM.INI, I/O mappings and application logic, including the applicable reset-coil advisory.
06	Complete offline validation and obtain approval before any controlled controller connection, download or online update.

04
SAFETY AND FINAL CHECKS

- The documented software license must be protected or transferred before uninstalling the Toolset. Investigate entitlement and release compatibility before changing the project.
- Review compilation, I/O mapping and application-validator results. Unexpected ladder behavior requires assessment against the complete manufacturer safety advisory.

05
OFFICIAL PROCEDURE

ICSTT-RM249 | PD-T8082 Issue 16 | Trusted Toolset Suite guide

PD-T8082 PDF pp. 18-21: workstation and licensing requirements; p. 22: configuration manager and engineering connection. Safety Advisory 2020-08-002 Rev. A PDF pp. 1-3: affected software and required review.

Rockwell Product Safety Advisory 2020-08-002 Rev. A | February 2025

Independent Amikon reference, not an OEM manual. Use the complete manufacturer instructions matching the actual hardware and firmware. No manufacturer pages are reproduced.

AMIKON PRODUCT SUPPORT

+86-18020776786

INFO@AMIKON.CN


AMIKONG.COM

06 ORIGINAL REFERENCE SCHEMATICS

ICS Triplex T8082D | Documented installation context

Original Amikon illustration based on the linked OEM pages. Logical arrangement only; not to scale and not an electrical wiring or manufacturer installation drawing.

A | EQUIPMENT ARRANGEMENT



Logical software and licensing relationship only; not a wiring diagram or authorization for a live controller change.

Review the complete release-specific license procedure and applicable manufacturer safety notices.

B | CONFIGURATION BOUNDARY

Match T8082D, its software key and the actual Toolset release. The documented software license must be protected or transferred before uninstalling the Toolset. Validate project compatibility and applicable manufacturer safety notices.

07 ORIGINAL MANUFACTURER DRAWING AND PROCEDURE LINKS

[Toolset components and scope - PDF page 1](#)

[Exact licensing variants - PDF page 19](#)

[License preservation and transfer - PDF page 21](#)

[Configuration manager connection context - PDF page 22](#)

If the viewer ignores the page target, enter the stated PDF page manually. Retain the full manufacturer warnings and approved maintenance plan; this reference does not authorize live work.