

MANUFACTURER DOCUMENT PACKAGE

Manufacturer's Manual

Reference package for procurement and maintenance review

SCHNEIDER

VW3A3607

COMMUNICATION MODULE

Used with the applicable Schneider Electric PROFIBUS option modules configuration.

REFERENCE PACKAGE

OFFICIAL DOCUMENT

Selected official manufacturer pages follow this cover.

Source: Schneider Electric VW3A3607 PROFIBUS DP-V1 User Guide

LXM32M

Profibus DP-V1 Module

User Guide

Original instructions

0198441113796.06

06/2021



Table of Contents

Safety Information.....	5
Qualification of Personnel	5
Intended Use.....	6
About the Book.....	7
Introduction	10
Fieldbus Devices on the Profibus Network.....	10
Basics	11
Conformance Classes.....	11
Network Topology	11
Data Structure	12
Cyclic Communication - Overview.....	13
Cyclic Communication - Structure of the Output Data	15
Cyclic Communication - Structure of the Input Data	16
Cyclic Communication - Parameter Channel.....	19
Cyclic Communication - Handshake via the "Mode Toggle" Bit	21
Acyclic Communication - Overview	22
Acyclic Communication - Example: Reading a Parameter	25
Controller as a Fieldbus Master	26
Installation	27
Installation of the Module	27
Commissioning.....	30
Preparation	30
Settings with the Configuration Tool of the Master	31
Operating States and Operating Modes.....	36
Operating States	36
Indication of the Operating State via Fieldbus.....	36
Changing the Operating State via Fieldbus	36
Operating Modes.....	37
Indicating an Operating Mode	37
Starting and Changing an Operating Mode	38
Overview of Operating Modes.....	39
Operating Mode Jog.....	39
Operating Mode Electronic Gear	40
Operating Mode Profile Torque	41
Operating Mode Profile Velocity	42
Operating Mode Profile Position.....	42
Operating Mode Homing	43
Operating Mode Motion Sequence	44
Diagnostics and Troubleshooting	45
Fieldbus Communication Error Diagnostics	45
Fieldbus Test.....	45
Fieldbus Status LEDs	45
Error Messages.....	46
Glossary	49
Index	51

Safety Information

Important Information

Read these instructions carefully, and look at the equipment to become familiar with the device before trying to install, operate, service, or maintain it. The following special messages may appear throughout this documentation or on the equipment to warn of potential hazards or to call attention to information that clarifies or simplifies a procedure.



The addition of this symbol to a “Danger” or “Warning” safety label indicates that an electrical hazard exists which will result in personal injury if the instructions are not followed.



This is the safety alert symbol. It is used to alert you to potential personal injury hazards. Obey all safety messages that follow this symbol to avoid possible injury or death.

DANGER

DANGER indicates a hazardous situation which, if not avoided, **will result in** death or serious injury.

WARNING

WARNING indicates a hazardous situation which, if not avoided, **could result in** death or serious injury.

CAUTION

CAUTION indicates a hazardous situation which, if not avoided, **could result in** minor or moderate injury.

NOTICE

NOTICE is used to address practices not related to physical injury.

Please Note

Electrical equipment should be installed, operated, serviced, and maintained only by qualified personnel. No responsibility is assumed by Schneider Electric for any consequences arising out of the use of this material.

A qualified person is one who has skills and knowledge related to the construction and operation of electrical equipment and its installation, and has received safety training to recognize and avoid the hazards involved.

Qualification of Personnel

Only appropriately trained persons who are familiar with and understand the contents of this manual and all other pertinent product documentation are authorized to work on and with this product. These persons must have sufficient technical training, knowledge and experience and be able to foresee and detect potential hazards that may be caused by using the product, by modifying the settings and by the mechanical, electrical and electronic equipment of the entire system in which the product is used.